

Barlow Water Improvement District

System Report

For February 2024 Board Meeting

January 2024 Water Pumped - Physical readings taken on 02/29/2024 (from 01/25/2024).

Well #2 – Not in operation during this period
Well #4 – Not in operation during this period
Well #6 - 2,226,234 gallons – 150.7 hrs – 246 gpm
Well #7- Not in operation during this period
Total - 2,226,234 gallons – 150.7 hrs
Average daily use – 63,606 gallons (35 Days)

Energy Cost January 2024 – \$1354.42 – total KWH 9,585. Total demand charges - \$504.53 (well #6 & #7).

Average daily use January 2023 – 52,310.78 gallons (28 days)

Energy Cost January 2023 - \$1307.05 – total KWH 10,793. Total demand charges- \$171.52 (well #4).