

Barlow Water Improvement District

System Report

For April 12, 2025 Board Meeting

March 2025 Water Pumped - Physical readings taken on 03/31/2025

Well #2 – NOT IN OPERATION

Well #4 – 2,418,920 gallons 215.2hrs

Well #6 – NOT IN OPERATION

Well #7- NOT IN OPERATION

Total - 2,418,920 gallons – 215.2 hrs

Average daily use – 78,029 gallons (31days)

Energy Cost March 2025 – \$1452.94 – total KWH 11,129 | Total demand charge \$299.20

Well # 6

Energy Cost March 2024 - \$1370.59 | KHW 13084 | Total demand charge \$293.28

Well # 6