

Barlow Water Improvement District

System Report

For December 13, 2025 Board Meeting

November 2025 Water Pumped - Physical readings taken on 11.27.2025

Well #2 – NOT IN OPERATION

Well #4 – 1,318,004 gallons – 174.20 hrs – 126 gpm

Well #6 – NOT IN OPERATION

Well #7- NOT IN OPERATION

Well #9 – NOT IN OPERATION

Total 1,318,004 – 174.20 hrs

Average daily use – 244,522 (30 Days)

Energy Cost November 2025 – \$1215.50 – | KWH 7827 | Total demand charge \$0

**Energy Cost November 2024 - \$1305.62 | KWH 9252 | Total demand charge \$297.10 -
Well#6**